

QUESTIONS & ANSWERS
SITE VISIT – WHSE DRAINAGE PROJECT
SOLICITATION SPM07014Q0032

1. What kind of reinforcement should be used in the walls of the drainage?

Answer: The contractor should comply with the specifications and provide an adequate reinforcement to be able to guarantee the work.

2. Will electricity be provided? Or do we need to bring a small generator?

Answer: Water connection and electrical outlets will be provided for the contractor to use. The contractor will need to bring extension **cords** and a hose to bring these **utilities** to the actual site.

3. Will the Embassy provide a space to store the materials while the project last?

Answer: Yes, we will provide space for the materials. The contractor shall not block any path with the materials.

4. What should be the final high of the drainage depth?

Answer: The contractor should use the current top of each corner as the final high.

5. Is the 1.50 to be level from the edge of the concrete or from the grill cover?

Answer: Contractor shall level and slope the surrounding grounds up to 1.5m from the edge of the concrete **slab** on each direction.

6. What should we use to fill the area around the drainage?

Answer: Contractor shall use gravel to leave the area around the drainage similar to the **adjacent** area around. The contract should use a compactor so the gravel is not left loose.

7. What kind of grills covers should be installed?

Answer: CAST IRON GRILLES COVERS must be for heavy traffic, 24"X24" nominal size, as manufactured by Fundaciones Panamericanas, SA Model No. MP-2424154 or similar.